



Industrie Service

# CERTIFICATE

(Certificate of conformity with technical requirements in: )  
**API STANDARD 607 SEVENTH EDITION, JUNE 2016**

Certificate No.:270881

Ref. Test report No.:270882

Name and postal address of applicant: **ValPro s.r.o.**  
**Kopcianska 10, Bratislava, Slovakia**

We hereby certify that the fire test on below valves have been conducted at the laboratory designated by manufacturer and witnessed by TÜV SÜD inspector according to requirements of API STANDARD 607 SEVENTH EDITION, JUNE 2016. The testing results of valves meet the requirements of API STANDARD 607 SEVENTH EDITION, JUNE 2016.

**1. Description of Test Valve :**

Type of Test Valve	Q347N-900LB-8"-AA3 Ball Valve
Description of Test Valve	Ball Valve
Valve Size (NPS)	8"
Pressure Rating ( Class )	Class 900
Valve Body Material	ASTM A350 LF2

**2. Qualified Range of Valves :**

Type	Ball Valves
Description of Valves	Ball Valves
Qualified Sizes ( NPS ) ( according to API 607 Table 3 )	8" and larger
Qualified Pressure Ratings( Class ) ( according to API 607 Table 4 )	Class 900, Class 1500
Qualified Valve Material	According to API 607 7.2
Remark: the technical data of tested valves see back of this certificate appendix 1.	

This certificate is issued according to API STANDARD 607 SEVENTH EDITION, JUNE 2016, based upon the result of testing report on above mentioned test valve. The additional valve qualification shall be limited on similar valves of same basic design and construction as the test valves and of the same nonmetallic materials as the test valve in the seat-to-closure member seal, seat-to-body seal, stem seal, and body joint and seal according to API STANDARD 607 SEVENTH EDITION, JUNE 2016, Paragraph 7.

**Shanghai, July 24, 2020**  
 (Place, date)

**Guilin Chen**  
**TÜV SÜD Industrie Service GmbH**  
 Westendstr.199  
 80686 München Germany



Industrie Service

**Appendix 1:**

**Certificate No.: 270881**

**Ref. Test report No.:270882**

**Name and postal address of applicant: ValPro s.r.o.  
Kopcianska 10, Bratislava, Slovakia**

**Technical Data of Valve**

**1. Type of Test Valve:** Q347N-900LB-8"-AA3 Ball Valve

**2. Description of Test Valve:** Ball Valve

**3. Details of Valve:**

Part Name	Valves Size ( NPS ) Material	8"
Body		ASTM A350 LF2
Bonnet		ASTM A350 LF2
Ball		ASTM A350 LF2+ENP
Seat Insert		DEVLON-V
Stem		ASTM A182 F6a
Gasket		SS304+Graphite
Lower Cap		ASTM A350 LF2
Packing		Graphite
Yoke		ASTM A216 WCB
Nuts		ASTM A194 7
Bolts		ASTM A320 L7
Screw		ASTM A320 L7
O-Ring		VITON
Spring		INCONEL X-750
Seat Ring		ASTM A350 LF2
Design Drawing No.:		AA3 2020-06-09-01

**Shanghai, July 24, 2020**

*(Place, date)*

TÜV SÜD Industrie Service GmbH  
Shanghai Office  
Floor 3-13, No.151, Heng Tong Road,  
Shanghai 200070 P. R. China

*Chen*  

**Guilin Chen**

**TÜV SÜD Industrie Service GmbH**

Westendstr.199  
80686 München Germany

Tel.: +86 21 6141-0123  
Fax: + 86 21 6140-8600

## Test Report

(Valve fire test according to API STANDARD 607 SEVENTH EDITION, JUNE 2016.)

Certificate No. :270881  
Test Report No.:270882

Applicant: ValPro s.r.o.  
Kopcianska 10, Bratislava, Slovakia

Inspection body: TÜV SÜD Industrie Service GmbH  
Floor 3-13, No.151, Heng Tong Road, Shanghai, P. R. China

Lab of test: Quality Inspecting Center of Pump and Valve Products of Zhejiang  
Province

Test Date: June 18, 2020

Description of valves: Q347N-900LB-8"-AA3 Valve  
Size:8"  
Pressure Rating: Class 900  
Drawing No.: AA3 2020-06-09-01


Test Witnessed By: WANG Zhilin / TÜV SÜD Inspector

## Inspection and Tests

### 1. Conformity of Equipment

The test equipment was verified by TÜV SÜD inspector according to requirements of API STANDARD 607 SEVENTH EDITION, JUNE 2016. Para.5.3 and found satisfactory. The detail arrangement of the fire-test equipment is shown below:

**Figure 1.** Typical Fire-Test System Using a Pump as the Pressure Source



a) Pump as pressure source

#### Key

- |   |   |                       |
|---|---|-----------------------|
| 1. Pressure source                          | 10. Test valve mounted horizontally<br>with stem in horizontal position | 19. Check valve       |
| 2. Pressure regulator and relief            |   | 20. Slope             |
| 3. Vessel for water                         | 11. Fuel gas supply and burner  | 21. Clearance: 150 mm |
| 4. Calibrated sight gauge                   | 12. Calorimeter cubes   |                       |
| 5. Water supply                             | 13. Flame environment and body thermocouples                            |                       |
| 6. Shut-off valve                           | 14. Pressure gauge and relief valve                                     |                       |
| 7. Pressure gauge                           | 15. Shut-off valve  |                       |
| 8. Piping arranged to<br>provide vapor trap | 16. Vent valve  |                       |
| 9. Enclosure for test                       | 17. Condenser   |                       |
|   | 18. Container   |                       |

Test Report No.:270882

2. Calibration of measurement and test instrument

The measurement and test instrument have been properly calibrated such as pressure gauges, thermocouples, etc.

3. Technical Data of Test Valve:

a) Description of test valve

Type of Test Valves	Q347N-150LB-8"-AA3 Ball Valve
Description of Valves	Ball Valve
Pressure Class	Class 900
Valve Size	8"
Face to Face	ASME B16.10
Designed Standard	API6D

b) Details of technical data on test valve

Part Name	Materials
Body	ASTM A350 LF2
Bonnet	ASTM A350 LF2
Ball	ASTM A350 LF2+ENP
Seat Insert	DEVLON-V
Stem	ASTM A182 F6a
Gasket	SS304+Graphite
Lower Cap	ASTM A350 LF2
Packing	Graphite
Yoke	ASTM A216 WCB
Nuts	ASTM A194 7
Bolts	ASTM A320 L7
Screw	ASTM A320 L7
O-Ring	VITON
Spring	INCONEL X-750
Seat Ring	ASTM A350 LF2
Design Drawing No.:	AA3 2020-06-09-01



**Test Report No.:270882**

4. Visual and dimensional Check on Valve Specimen:

The specimen valve was chosen at random by the manufacturer in its workshop and submitted to the laboratory. The visual and dimensional check was performed according to drawing No. AA3 2020-06-09-01 and results found satisfactory. The mark was verified on valve as following:

<u>--</u>	<u>8"</u>	<u>600</u>	<u>LF2</u>
Manufacturer` Brand	Size	Class	Material

The sample valve was equipped with a worm gearbox.

5. Document Review:

The chemical and mechanical test report of forgings was reviewed and found satisfactory. Also the inspection report of shell test, hydro seat test and air seat test were reviewed and found satisfactory.

6. Preparation before testing:

6.1 The thermocouples and calorimeters were installed properly according to Figure 1,2,3,4 in API 607.

Two thermocouples (part 13) are installed to measure flame temperature, one is located under valve body, another is located under valve stem, both within 1". Two calorimeters (part 12) are positioned to the same place as the thermocouples do, and a third one is positioned nearby the bottom cover.

6.2 The test system including test valve (part 10) was cleaned through by water before testing. All air was purged from test valve and testing system by water.

6.3 The test system was pressurized to 21.5 MPa after the test valve and system upstream of valve have been completely full of water and system downstream of the test valve have been completely empty of water. The system and test valve were carefully checked for leakage when the test pressure was held at 21.5 MPa. No leakage was found on system and test valve.

7. Fire Test:

The fire test was conducted according to API STANDARD 607 SEVENTH EDITION, JUNE 2016. Section 5. The pressure of the system upstream was kept 11.5 MPa, then the fire ignited. The flame temperature reached 750°C within 2 minutes after ignition. The test pressure and temperature were maintained at 11.5 MPa during the fire test. The temperature and pressure were recorded continuously by the operators. The system and test valve was cooled below 100°C within 9 minutes by shower nozzles after 30 minutes fire test. The loss of water weight in vessel was measured by weighing scale and water in calibrated container (part 18) were read and recorded. The test result is shown as below:

Test Report No.:270882

Test result of fire test

Item	API 607 Required Value	Actual Value
Test Pressure ( MPa )	11.5 MPa	11.0– 12.0 MPa
Test Temperature	750 - 1000 °C	771 – 804.5°C
Through-valve leakage according to API 607 table 1	≤ 3200 ml / minute	383.3 ml / minute
Total weight of water through valve seat during cooling down period	0 ml	
Total time from fire test to cooling down	39 Minutes	
External Leakage	≤ 800 ml / minute	0 ml / minute
Conclusion: the test result is satisfactory according to API 607.		

8. Operational Test:


The test valve was cooled below 100°C within 9 minutes after complete the fire test. The operational test was conducted according to API STANDARD 607 SEVENTH EDITION, JUNE 2016.Para. 6.6 and 5.6.17. The upstream pressure was increased to 11.5 MPa then the test valve was fully opened against the high test pressure differential to vent the piping and test valve body cavity to remove air or steam. The downstream shutoff valve was then closed and the system pressure was increased to and maintained at 11.5 MPa. Then measured and recorded external leakage for a period of five minutes after valve was in the open position at high test pressure. The test result was recorded as below:

Test result of operational test

Item	API 607 Required Value	Actual Value
Test Pressure ( MPa )	11.5 MPa	11.5 MPa
Test Temperature	30 °C	
Test Time	5 minutes	
External Leakage	≤ 200 ml / minute	16 ml / minute
Conclusion: the test result is satisfactory according to API 607.		

The undersigned, hereby declare that I have checked test valve and witnessed the fire test on the test valve according to API STANDARD 607 SEVENTH EDITION, JUNE 2016. The test result is satisfactory.

TÜV SÜD Industrie Service GmbH



Date: July 24, 2020

WANG Zhilin

Annexes:

- 1) Copy of Drawing No. AA3 2020-06-09-01;
- 2) Copy of Test Record of Fire Test No. WFM202006131.